



**SETBACK INFORMATION FOR
HOMES AND ACCESSORY
STRUCTURES IN RESIDENTIAL ZONES
7-1-2016**

400 SW 152nd Street, Suite 300 Burien, WA 98166 Phone: (206) 241-4647 • FAX: (206) 248-5539 www.burienwa.gov

The Community Development Department uses the information below to evaluate a project's compliance for setbacks to property lines.

- The Zoning codes determine *how far* something can project on the property.
- The Building codes determine if the construction meets minimum fire separation distance and requires minimum fire-resistance rated materials when components are less than 5 feet from a property line.

MINIMUM ZONING SETBACKS	FRONT (STREET FACING)	SIDE & REAR	OTHER
HOME	20 feet	5 feet	
GARAGE & ACCESSORY STRUCTURES	20 feet	5 feet	10 feet setback to alley
PROJECTIONS (Allowed into the Setback)			
• Eaves	24 inches	18 inches	
• Fireplace structures, bay or garden windows, enclosed stair landings or similar structures	30 inches	24 inches	<ul style="list-style-type: none"> • Limited to 2 per façade • Maximum 10 feet each • Maximum 50% of façade
• Uncovered porches & decks - more than 18" above grade	5 feet	18 inches	
• Uncovered porches and decks – 18" or less above grade	May project to the property line	May project to the property line	

MINIMUM INTERNATIONAL RESIDENTIAL CODE SET BACK FOR EXTERIOR WALL ELEMENT		MINIMUM FIRE RESISTANCE RATING	MINIMUM FIRE SEPARATION DISTANCE
WALLS	Fire-resistance rated	1 hour—tested in accordance with ASTM E 119 or UL 263 with exposure from both sides	< 5 feet
	Not Fire-resistance rated	0 hours	≥ 5 feet
PROJECTIONS • Eaves, overhangs	Fire-resistance rated	1 hour on the underside ^{a,b}	≥ 2 feet to < 5 feet
	Not Fire-resistance rated	0 hours	≥ 5 feet
OPENINGS IN WALLS • Doors, windows, Vents, exhaust fans	Not allowed	N/A	<3 feet
	Maximum 25% of wall area per story	0 hours	≥ 3 feet to 5 feet
	Unlimited	0 hours	≥ 5 feet
PENETRATIONS • Piping, Electrical Services	ALL	Comply with Section R302.4	< 5 feet
		None Required	≥ 5 feet

- a. Roof eave fire-resistance rating shall be permitted to be reduced to 0 hours on the underside of the eave if fire blocking is provided from the wall top plate to the underside of the roof sheathing.
- b. Roof eave fire-resistance rating shall be permitted to be reduced to 0 hours on the underside of the eave provide no gable vent openings are installed.

NOTE: SEE IRC TABLE R302.1(2) FOR HOMES EQUIPPED WITH FIRE SPRINKLERS